

TOWN OF TRUMBULL, CONNECTICUT
BOARD OF EDUCATION

REQUEST FOR BIDS

INSTALLATION OF AUTOMATIC GREASE RECOVERY UNITS IN SEVEN SCHOOLS

BID NUMBER: 5908

DUE: AUGUST 3, 2011 @ 2:00PM

GENERAL QUESTIONS/ANSWERS FOR ALL POTENTIAL BIDDERS

The following questions and answers were submitted by a prospective bidder on the Automatic Grease Trap Unit Installation bid # 5907. The answers to these questions were provided by the engineer.

Where there are existing two inch drain connections, can two inch connections be used rather than three as noted in the specifications?

Yes. Where there are existing two inch drains and connections to the waste line, this is fine. However, any larger existing drains or connections cannot be reduced.

Can PVC pipe be used instead of cast iron or copper?

The pipe used should be determined by what is there currently. If PVC is used, than PVC can be used.