

TOWN OF TRUMBULL, CONNECTICUT  
BOARD OF EDUCATION

REQUEST FOR QUOTATION

INSTALLATION OF GAS LINES AND GAS TRAINS AT FOUR SCHOOLS

BID NUMBER: 5917

DUE: JANUARY 4, 2012 @ 2:00PM

ADDENDUM 1

1. In answer to a question: Boilers and dual fuel burners are currently in place.
2. In answer to a question: Southern CT Gas Company has installed the supply lines and meters to each school.
3. The Board of Education uses Power Flame burners and parts. To assist bidders a list of parts necessary to assemble the gas trains at each location has been attached to this Addendum (Appendix A). This list is offered to assist the bidders. It is the bidder's responsibility to verify the list for completeness and accuracy.
4. The gas lines running to each boiler must be sized to allow both boilers to fire simultaneously.
5. Before start-up, the installer must make sure that the burners' gas orifices have been completely cleaned of carbon to allow proper firing of each boiler on gas.
6. There is a correction for the last day for inquiries. The last day for inquiries is 12-30-11.

Addendum to Bid # 5917 – December 20, 2011 - Appendix A

Daniels Farm School:

Qty.	Description
4	PF # M20431 - 1 1/2" BALL VALVE
2	HW # V5055C - 1059 - 1 1/2" GAS VALVE BODY
2	HW # V4062D - 1002 - LOW-HIGH-LOW VALVE ACTUATOR
2	K3AG82U - 1 1/2" AUXILARY GAS SOLENOID VALVE
4	PF # 980030 - 1/4" LGAK TEST COCKS
2	PF # 161000 - LOW GAS PRESSURE SWITCH
2	PF # 161100 - HIGH GAS PRESSURE SWITCH
2	MAXITROL 210D - 1 1/2" MAIN GAS PRESSURE REGULATOR
2	PF # 911530 - ORIFICE SPRING
2	ORIFICE
2	PF # X02353 - 2" x 12 NIPPLE
2	PF # 873420 - 2" TEE
2	PF # M15013 - 2" PIPE PLUG DRILLED AND TAPPED
2	PF # Y00470 - 5/16" GALVANIZED ROD
4	PF # 911000 - SWIVEL JOINTS FOR 5/16" ROD

Booth Hill School:

Qty.	Description
4	PF # M20431 - 1 1/2" BALL VALVE
2	HW # V5055C - 1059 - 1 1/2" GAS VALVE BODY
2	HW # V4062A - LOW-HIGH-LOW VALVE ACTUATOR
2	K3AG82U - 1 1/2" AUXILARY GAS SOLENOID VALVE
4	PF # 980030 - 1/4" LGAK TEST COCKS
2	PF # 161000 - LOW GAS PRESSURE SWITCH
2	PF # 161100 - HIGH GAS PRESSURE SWITCH
2	MAXITROL 210D - 1 1/2" MAIN GAS PRESSURE REGULATOR
2	PF # 911530 - ORIFICE SPRING
2	ORIFICE
2	PF # X02353 - 2" x 12 NIPPLE
2	PF # 873420- 2" TEE
2	PF # M15013 - 2" PIPE PLUG DRILLED AND TAPPED
2	PF # Y00470 - 5/16" GALANIZED ROD
4	PF # 911000 - SWIVEL JOINTS FOR 5/16" ROD
2	PF # 202650 - 3/8" PILOT GAS VALVE
2	MAXITROL 325-3 PILOT REGULATOR

Tashua School:

Qty.	Description
4	PF # M20431 - 1 1/2" BALL VALVE
2	HW # V5055C - 1059 - 1 1/2" GAS VALVE BODY
2	HW # V4062D - 1002 - LOW-HIGH-LOW VALVE ACTUATOR
2	K3AG82U - 1 1/2" AUXILARY GAS SOLENOID VALVE
4	PF # 980030 - 1/4" LGAK TEST COCKS
2	PF # 161000 - LOW GAS PRESSURE SWITCH
2	PF # 161100 - HIGH GAS PRESSURE SWITCH
2	MAXITROL 210D - 1 1/2" MAIN GAS PRESSURE REGULATOR
2	PF # 911530 - ORIFICE SPRING
2	ORIFICE
2	PF # X02320 - 2 1/2" x 12 NIPPLE
2	PF # 873460 - 2 1/2" TEE
2	PF # M15014 - 2 1/2" PIPE PLUG DRILLED AND TAPPED
2	PF # Y00470 - 5/16" GALANIZED ROD
4	PF # 911000 - SWIVEL JOINTS FOR 5/16" ROD

Jane Ryan School:

Qty.	Description
4	PF # M20431 - 1 1/2" BALL VALVE
2	HW # V5055B - 1028 - 1 1/2" GAS VALVE BODY
2	HW # V4062A - 1008- LOW-HIGH-LOW VALVE ACTUATOR
2	K3AG82U - 1 1/2" AUXILARY GAS SOLENOID VALVE
4	PF # 980030 - 1/4" LGAK TEST COCKS
2	PF # 161000 - LOW GAS PRESSURE SWITCH
2	PF # 161100 - HIGH GAS PRESSURE SWITCH
2	MAXITROL 210D - 1 1/2" MAIN GAS PRESSURE REGULATOR
2	PF # 911530 - ORIFICE SPRING
2	ORIFICE
2	PF # X02353 - 2" x 12 NIPPLE
2	PF # 873420- 2" TEE
2	PF # M15013 - 2" PIPE PLUG DRILLED AND TAPPED
2	PF # Y00470 - 5/16" GALANIZED ROD
4	PF # 911000 - SWIVEL JOINTS FOR 5/16" ROD
2	PF # 202650 - 3/8" PILOT SOLENOID VALVE
2	MAXITROL 325-3 PILOT REGULATOR