

TOWN OF TRUMBULL, CONNECTICUT

TRUMBULL TOWN HALL ROOF REPLACEMENT
AND
TRUMBULL POLICE DEPARTMENT ROOF REPAIRS
TRUMBULL, CONNECTICUT 06611

RFQ #5946 DUE: MAY 10, 2012 at 3:00PM

ADDENDUM 1

This Addendum shall be part of the Contract Documents and modifies the original bidding documents. This Addendum is to be acknowledged by the bidders on the Bid Form. Failure to do so may subject the bidder to disqualification. **The bid date remains May 10, 2012.**

It is the responsibility of the General Contractor to coordinate this work with all affected subcontractors. All parts and materials shall be included to complete the work and to properly integrate with adjacent work or existing conditions.

Changes to Drawings:

1) **Drawing A-110 – Town Hall Roof Plan**

a.) On Drawings A-110, add the following construction note adjacent to RTU-2 and RTU-4:

Note #14 – Contractor shall remove and re-install the existing ductwork at RTU-2 and RTU-4 in order to properly install the new roofing system. This work shall be a part of the based bid.