

ADDENDUM #1

8 November 2013

RE: TOWN OF TRUMBULL
PUBLIC WORKS FACILITY
ROOF REPLACEMENT

FROM: ANTINOZZI ASSOCIATES, P.C.

TO: PROSPECTIVE BIDDERS

Page 1 of 1

This Addendum shall be part of the Contract Documents and modifies the original bidding documents. This Addendum is to be acknowledged by the bidders on the Bid Form. Failure to do so may subject the bidder to disqualification. **The bid date remains November 14, 2013.**

It is the responsibility of the General Contractor to coordinate this work with all affected subcontractors. All parts and materials shall be included to complete the work and to properly integrate with adjacent work or existing conditions.

Clarifications:

1) On Drawing A-100, revise Alternate Bid #1 For S2 Area note to read as follows:

Remove existing roofing system complete including plywood deck. Install new roofing system as specified including new 3/4" CDX T&G plywood deck. Provide new 2x12 rafters sistered to existing 2x10 rafters. Unfasten existing metal diagonal bridging and install new solid 2x12 blocking for entire length of S2 roof area (2 rows). All Alternate Bid #1 work for S2 roof area to be completed from above roof. No work will take place within building. Existing drywall ceiling, batt insulation, light fixtures, etc. mounted to the roof structure to remain.

2) All drawings are not to scale. Bidders to verify all dimensions before submitting their bid.

END OF ADDENDUM #1

271 Bridgeport Avenue
Bridgeport, CT 06604
Tel: 203.377.1300 Fax: 203.378.3002



ANTINOZZI ASSOCIATES
ARCHITECTURE & INTERIORS