

FROM: ANTINOZZI ASSOCIATES
271 FAIRFIELD AVENUE
BRIDGEPORT, CT 06604

TO: ALL BIDDERS

RE: JOB NO. 14046
TOWN OF TRUMBULL
MARY J. SCHERLACH COUNSELING CENTER
RENOVATIONS & ALTERATIONS
121 OLD MINE ROAD, TRUMBULL, CT

SUBJECT: ADDENDUM NO. 2

DATE: OCTOBER 22, 2014

This Addendum shall be part of the Contract Documents for the referenced Bid. The Addendum is to acknowledge by the bidder on the Bid Form.

The following ADDENDUM is issued to clarify items appearing either in the specifications or on the Drawings, said items having been called to the attention of the Architect by one or more of the Contractors estimating the work:

The Specifications and / or drawings are amended as follows:

1. SPECIFICATION – SECTION 16010 GENERAL PROVISIONS FOR
ELECTRICAL WORK

A. Clarification – Fire rated cable may be used in lieu of EMT Conduit for the Fire Alarm System.

2. DRAWING – A-101

A. Construction Note #33 – The scope of work for construction note #33 shown on the First Floor Plan is as follows: Backfill and compact all areas of removals from ramp work. Restore affected areas to original condition including but not limited to fill material, topsoil, lawn seeding and crushed stone.

END OF ADDENDUM NO. 2