

TOWN OF TRUMBULL
REQUEST FOR PROPOSAL
FOOD SERVICE EQUIPMENT
TASHUA AND BEACHES POOL CONCESSION STAND

BID # 6178

DUE: APRIL 21, 2016 @ 2:00 PM

GENERAL INSTRUCTIONS TO BIDDERS

ADDENDUM # 2

Amended 4-182016

This addendum is issued for Clarification on questions that were asked after Health inspection:

Below is a list of requirements of the Health Department provided to one of the potential bidders following an inspection of the premises. For the purpose of this bid, bidders should assume all of this is the responsibility of the concessionaire with the exception of the screen door which will be provided by the Town.

Tashua

- Cover lights
- Clean floors
- Indirect waste under 3 bay sink is needed
- Replace rusted equipment

Beaches

- Walls need to be cleaned/painted and coving on wall needs to be fixed
- Clean floors
- Clean shelving
- Provide new door screen
- Replace rusted equipment

A grease trap will need to be installed at both locations.

Shaquaisha Andrews
Sanitarian
Trumbull Health Department
203-452-1033

Inquiries of a technical nature may be directed to Mr. Stuart McCarthy <smccarthy@trumbull-ct.gov> (203 452-5064) or dparis@trumbull-ct.gov; all other questions for this RFP may be directed to Mr. Kevin Bova, Purchasing Agent (203-452-5042) kbova@trumbull-ct.gov