

TOWN OF TRUMBULL, CONNECTICUT
BOARD OF EDUCATION

REQUEST FOR QUOTATION

REPLACEMENT OF CHILLER COMPRESSOR AT TRUMBULL AGRISCIENCECENTER

BID NUMBER: 5984

DUE: MAY 14, 2013 @ 2:00PM

ADDENDUM – 1

The compressor oil has been tested and it is non-acidic. Therefore, the refrigerant will not need to be reclaimed.

In addition, the filter drier cores do not need to be replaced.

Please adjust your bid accordingly.

All other requirements, terms and conditions remain the same