

**TRUMBULL FIRE  
MARSHAL'S OFFICE**

[firemarshal@trumbull-ct.gov](mailto:firemarshal@trumbull-ct.gov)

***Town of Trumbull  
Connecticut***



**Town Hall**  
5866 Main Street  
Trumbull, Connecticut 06611

203.452.5080  
Fax: 203.452.5093

**2014 TRUMBULL DAY FIRE SAFETY GUIDELINES**

**Electrical**

1. All extension cords must be of the proper sized wire to carry the amperage required to operate the particular appliance and must be of the three-wire type.
2. All appliances must be grounded.
3. The use of three-prong to two-prong adapters is not acceptable.
4. All provisions of the National Electrical Code must be complied with.
5. The use of electrical cubes is not acceptable.
6. All electrical boxes must have covers.
7. Any electrical cord running across any walkway must be protected to prevent anyone from tripping over it.
8. Lighting must be protected to prevent anyone from touching and receiving a burn.
9. All lights must be isolated from any metal poles or steel guide wires.

**Gas Powered Generators**

1. Must be fenced off to protect anyone from touching or being able to come in contact with.
2. Must have the minimum of a 10 ABC type extinguisher.
3. Must have an earth ground.
4. Must have an exhaust system.
5. All gas storage containers must be properly identified and must meet the requirements of the Fire Safety Code.
6. Gas containers shall not be stored inside any display area or within 5 ft of any generator.
7. No generator of any type shall be run in any vehicle.

**TRUMBULL FIRE  
MARSHAL'S OFFICE**

[firemarshal@trumbull-ct.gov](mailto:firemarshal@trumbull-ct.gov)

**Town of Trumbull  
Connecticut**



**Town Hall**  
5866 Main Street  
Trumbull, Connecticut 06611

203.452.5080  
Fax: 203.452.5093

**Propane Tanks**

1. Must be 3 ft from building.
2. Must have stakes and be tied off.
3. Must be a minimum of 5 ft from burner.
4. All fittings and piping must meet propane gas standards.
5. After system is connected, it must be checked for leaks.
6. Must have a minimum of two (2) 10 ABC type extinguishers.
7. No copper tubing shall be run underground or where pedestrian traffic can cross it. Rubber hose with the proper fittings meeting propane gas installation requirements shall be used.

**Tents**

1. All tents must be flame resistive and have certification stickers on them.
2. All stakes must be covered with boots to prevent injury.

**Special Lighting**

Kerosene, Propane, Coleman fluid or any other type of gas or lantern fuel fire lights are PROHIBITED from use.

**Fireworks**

**No fireworks** shall be sold by any vendor. If found in any vendors display they will be confiscated and the vendor will be arrested and asked to leave the Trumbull Day grounds.

**NOTE:** In addition to the above listed guidelines, all regulations of the State Fire Safety Code must be met.

*Megan M. Murphy*  
Fire Marshal  
Town of Trumbull