

ADDENDUM NO. 5

5.1 Clarification

- a. Copy of the Environmental/Hazardous Materials Site Assessment Report prepared by Cardno dated November 19, 2014 (updated March 13, 2015) is available at the Stern Village Management Office for review by all Bidders. Bidders, shall by submitting their bid represent they have in fact reviewed and are familiar with the contents of the report.
- b. The Cardno Report identifies unit numbers where contaminated joint compound is located apparently in the older units.
- c. Penetrations through contaminated joint compound shall be performed by a licensed Abatement Contractor shall be included in the Base Bid Amount. Base Bid shall include all labor, materials, appliances and testing if required to complete penetrations required new work through contaminated joint compound.

5.2 Clarification

- a. Scope of work to be performed by a State of Connecticut licensed Abatement Contractor shall include;
 - a. Cutting holes for penetrations required to complete the installation of the interior air handle wall mounted units.
 - b. Increased openings around existing Murray power panels to accommodate the complete installation of the new larger power panels.
 - c. Cutting of the new openings for the proposed Alternate Transfer Grilles.

Attachments: NONE

End Addendum No.5