

TO: ALL BIDDERS

TOWN OF TRUMBULL  
TRUMBULL SENIOR CENTER  
KITCHEN RENOVATIONS  
23 PRISCILLA PLACE, TRUMBULL, CT

SUBJECT: ADDENDUM NO. 1

DATE: JUNE 13, 2018

---

This Addendum shall be part of the Contract Documents for the referenced Bid. The Addendum is to acknowledge by the bidder on the Bid Form.

---

The following ADDENDUM is issued to clarify items appearing either in the specifications or on the Drawings, said items having been called to the attention of the Architect by one or more of the Contractors estimating the work:

The Specifications and / or drawings are amended as follows:

1. GENERAL ITEMS –

- A. Remove all existing supply and return diffusers in Dining Room and replace with new to match existing.
- B. Contractor to include in his base bid, costs to snake out existing kitchen sanitary line out to main sanitary line located in parking lot directly adjacent to kitchen.

All technical inquiries regarding this request shall be answered by Paul Lisi – Antinozzi Associates (203-377-1300) [PLisi@Antinozzi.com](mailto:PLisi@Antinozzi.com) . All other questions may be directed to Kevin J. Bova Purchasing Agent (203.452.5042) [kbova@trumbull-ct.gov](mailto:kbova@trumbull-ct.gov)

END OF ADDENDUM NO. 1